



FORM B 13.3

FIRE SAFETY CERTIFICATE RENEWAL (FSCR)

(See Rule 25)

Fire Safety Certificate Approval (FSCA) No. FSCA/O/RFOGAN/2024/00065958

Date: 24/06/2024

FSC Safety Certificate Renewal (FSCR) No. FSCA/O/RFOGAN/2024/00065958/R1

Building Occupancy/Category: Educational (non-residential)

To,

Bipinchandra Patel

Mahesana Unjha Highway, Motidau, Dist.Mahesna Mahesana Unjha Highway, Motidau, Dist.Mahesna Mahesana Unjha Highway, Motidau, Dist.Mahesna Motidau MEHSANA Mahesana 384310

Fire Region: Gandhinagar RFO

Mobile No: 9924446438 Email ID: bipin@anmschool.com

This has reference to your Application No.2024/00066161 dated 13/06/2024 for Fire Safety Certificate Renewal (FSCR) for the building/premise Anand Niketan School (name of the Building/ Project), as per below mentioned details:

1. TP Number:
2. FP Number:
3. Survey Number:
4. Village Name: Motidau
5. Name of Block(s): 1

The building/premise was inspected on 24/06/2024 and all fire prevention, life safety and fire protection measures provided were found to be in proper and effective working condition. There are no changes in building/premise use or occupancy or in building design or structure.

Further, the following activities (as applicable) have been carried out towards meeting requirements of GFP&LSM Act-2013, GFP&LSM Rules-2014 & GFP&LSM Regulations-2023 as amended, or the then applicable GDCR:

1. Emergency drill was carried out on 24/06/2024
2. Six monthly inspection was done on 24/06/2024

The Fire Safety Certificate is renewed for a period of two (2) years upto 24/06/2026 in accordance with GFP&LSM Act-2013, GFP&LSM Rules-2014 & GFP&LSM Regulations-2023 and their amendments.



Digitally Verified

Digitally verified by: Zanzarukiya Gunvantkumar Bhailalbhai
Fire Safety Officer - General (FSO-G)
2021/001744

Date: 24/06/2024

Time: 02:19 PM



FSCA/O/RFOGAN/2024/00065958/R1

This is a digitally verified certificate, hence doesn't require physical signature. To validate authenticity of this certificate, scan the QR code or search the certificate details in appropriate section at www.gujfiresafetycop.in.

Please note that, apart from renewal, the building needs to be inspected every six months and a mock fire and emergency drill also needs to be conducted every six months. If there is a delay in scheduled inspection or mock drill, penalty shall be imposed. The Fire Safety Certificate renewal should be done timely after two years to avoid penalties.



Digitally Verified

Digitally verified by: Zanzarukiya Gunvantkumar Bhailalbhai
Fire Safety Officer - General (FSO-G)
2021/001744

Date: 24/06/2024
Time: 02:19 PM



FSCA/O/RFOGAN/2024/00065958/R1

This is a digitally verified certificate, hence doesn't require physical signature. To validate authenticity of this certificate, scan the QR code or search the certificate details in appropriate section at www.gujfiresafetycop.in.

Please note that, apart from renewal, the building needs to be inspected every six months and a mock fire and emergency drill also needs to be conducted every six months. If there is a delay in scheduled inspection or mock drill, penalty shall be imposed. The Fire Safety Certificate renewal should be done timely after two years to avoid penalties.